



HBOR.EX16453 - Hydrants

Hydrants

See General Information for Hydrants

SFFECO GLOBAL FZE (FORMALLY SAUDI FACTORY FOR FIRE EQUIPMENT FZCO)

EX16453

S-10833
 JEBEL ALI FREE ZONE
 AUTHORITY SOUTH 1
 DUBAI, UNITED ARAB EMIRATES

Base-valve design:

Model	Base-valve Size, in.	Hose Outlet (No. of Outlets), in.	Pumper Outlet (No. of Outlets), in.	Rated Pressure, psig
SF-F-06	5-1/4	(2) 2-1/2	—	250
SF-F-06	5-1/4	(2) 2-1/2	(1) 4, 4-1/2 or 5 in. threaded or 5 nonthreaded	250
SF-F-06	5-1/4	(3) 2-1/2	(1) 4, 4-1/2 or 5 in. threaded or 5 nonthreaded	250
SF-F-06	5-1/4	(4) 2-1/2	—	250
SF-F-06	5-1/4	(2) 2-1/2	(2) 4, 4-1/2 or 5 in. threaded or 5 nonthreaded	250
SF-F-06A	5-1/4	(2) 2-1/2	(1) 4-1/2	250
SF-F-06AF	5-1/4	(2) 2-1/2	(1) 4-1/2	250

Model SF-F-06 may incorporate a 3 or 4 in. monitor flange.

Model SF-F-06 hydrant may be supplied with a 3 or 4 in. flanged monitor elbow.

Model SF-F-06 is a "traffic type" when equipped with a breakaway traffic flange.

Wet-barrel design:

Model	Hose Outlet (No. of Outlets), in.	Pumper Outlet (No. of Outlets), in.	Rated Pressure, psig
SFD-250-WH	(2) 2-1/2	-	250
SFD-250-WH	(2) 2-1/2	(1) 4 or 4-1/2 in. threaded or 5 in. nonthreaded	250
SFD-250-WH	(1) 2-1/2	(1) 4 or 4-1/2 in. threaded or 5 in. nonthreaded	250

Wet-barrel design:

Model	Hose Outlet (No. of Outlets), in.	Pumper Outlet (No. of Outlets), in.	Rated Pressure, psig
SFD-250-WH-1	(2) 2-1/2	(1) 4-1/2	250

SFD-250-WH-2	(2) 2-1/2	(1) 4-1/2	250
SFD-250-WH-3	(2) 2-1/2	(1) 4	250
SFD-250-WH-4	(2) 2-1/2	(1) 4	250
SFD-250-WH-5	(2) 2-1/2	N/A	250
SFD-250-WH-6	(2) 2-1/2	N/A	250
SFD-250-WH-7	(1) 2-1/2	(1) 4-1/2	250
SFD-250-WH-8	(1) 2-1/2	(1) 4-1/2	250
SFD-250-WH-9	(1) 2-1/2	(1) 4	250
SFD-250-WH-10	(1) 2-1/2	(1) 4	250

Model SFD-250-WH hydrant may incorporate a 3 or 4 in. size monitor flange on the top of the hydrant.

Trademark and/or Tradename: "SFFECO",



Last Updated on 2021-02-02

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"